

## Certificate of constancy of performance,

**0832-CPR-F1152**

In compliance with Regulation 305/2011/EU of the European Parliament and of the council of 9<sup>th</sup> March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

### **ID100 Conventional Optical Smoke Detector**

*(For full product details and conditions of use refer to appendix)*

Produced by or for

#### **INIM ELECTRONICS S.R.L**

**Via Fosso Antico snc – Fraz. Centobuchi  
63076 Montepandone (AP)  
Italy**

and produced in the manufacturing plant(s)

#### **INIM ELECTRONICS S.R.L**

**Via Fosso Antico snc – Fraz. Centobuchi  
63076 Montepandone (AP)  
Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

### **EN 54-7:2000 + A1:2002 + A2:2006 - Smoke detectors - Point detectors**

under system 1 are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on 08 February 2016 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.



M McCullagh, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 08 February 2016  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).

## Appendix to Certificate of constancy of performance 0832-CPR-F1152

**Bases:**

EB0010 Standard base

EB0020 Relay base

**Sensitivities:**

Meets EN 54-7:2000 with 'low', 'medium-low', 'medium-high' and 'high' sensitivities.



M McCullagh, Certification Manager  
On behalf of BRE Global Limited  
Date of issue: 08 February 2016  
Issue number: 01

This certificate remains the property of BRE Global Ltd and is issued subject to terms and conditions.  
To check the validity of this certificate, please contact us on +44 (0)1923 664100 or email [enquiries@breglobal.com](mailto:enquiries@breglobal.com).